



VENTING

JOBOX[®] SAFETY TIPS:

- According to NFPA 30, venting a flammable storage cabinet is not necessary for fire protection purposes.
- If cabinet is not being vented, keep bungs secured in place.
- Always check with your local fire marshal or inspector, EHS Representative, MSDS, and industrial hygienist to determine if your cabinet should be ventilated.